



NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
- 2.*AN SBS BACKER PLY EXTENDING 2" MIN. FROM TOE OF CANT IS REQUIRED FOR EXTENDED TERM 25 AND 30 YEAR GUARANTEES.
- 3.*A TERMINATION BAR FASTENED 6" O.C. IS AN ACCEPTABLE SECUREMENT ALTERNATIVE ALONG THE TOP EDGE OF THE FLASHING.
4. EXTEND VENTSULATION ONE INCH MIN. PAST TOP OF BASEFLASHING TO PROMOTE AIRFLOW.
5. METAL COUNTER FLASHING IS RECOMMENDED FOR ALL INSTALLATIONS AND IS REQUIRED FOR ALL GUARANTEES 15 YEARS OR LONGER. A 3 COURSING OF PERMAFLASH MAY BE USED TO SEAL THE TOP EDGE OF THE FLASHING ON 10 YEAR NDL'S IN LIEU OF METAL COUNTER FLASHING.
6. ANY CARPENTRY, METAL WORK, OR MASONRY CONSTRUCTION SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
7. VERTICAL JOINTS ARE TO BE OVERLAPPED 4" MINIMUM FOR ALL APPLICATIONS. 3 COURSING WITH MBR UTILITY CEMENT AND FABRIC OR JM MBR FLASHING CEMENT IS RECOMMENDED ON ALL VERTICAL FLASHING LAPS. IT IS REQUIRED ON INSIDE/OUTSIDE CORNERS EXTENDING PAST LEADING EDGE OF CANT STRIPS.
8. PLEASE SEE BITUMINOUS FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
9. DYNASET 1K ADHESIVE RIBBONS REQUIRE 6" MINIMUM CROSS VENTING BREAK SPACED 33' MAXIMIM WITH ONE BREAK PER ROLL OF 1 SQUARE JM APPROVED SBS VAPOR RETARDER STAGGERED 10' MINIMUM.

DRAWING NO.

DS1K-1

FLASHING WALL DFE-28

DYNASET 1K RIBBON ADHERED BASE PLY

MEMBRANE TYPE:
BUR

MAXIMUM GUARANTEE TERM:

SCALE
N.T.S

ISSUE DATE
06-06-22

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Manville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction.

