

- 3. SYSTEM COMPONENTS AND DESIGN MUST BE VERIFIED TO BE IN ACCORDANCE WITH THIS LAYOUT.
- 4. ASCE-7 DEFINES THE PERIMETER (X) AS THE LESSER OF 10% OF THE LEAST HORIZONTAL DIMENSION OR .4 x THE HEIGHT, BUT NOT LESS THAN 4% OF THE LEAST HORIZONTAL UNDER 60 FEET IN HEIGHT. OVER 60 FEET IN HEIGHT, ASCE-7 DEFINES THE PERIMETER (X) AS THE LESSER OF 10% OF THE LEAST HORIZONTAL DIMENSION ONLY.
- 5. THE CORNERS MAY BE TREATED AS PERIMETERS IF THE PARAPET IS GREATER THAN OR EQUAL TO 3 FEET ACCORDING TO ASCE-7.

INSTALLATION NOTES:

- A. ALL INSULATION/COVER BOARDS SHOULD BE 4'-0" x 4'-0".
- B. WHEN APPLYING MULTIPLE LAYERS OF INSULATION, IT IS REQUIRED TO RUN THE BEADS PARALLEL TO THE PRECEDING LAYER WHEN USING JM APPROVED URETHANE ADHESIVE.
- C. DYNASET 1K ADHESIVE RIBBONS REQUIRE 6" MINIMUM CROSS VENTING BREAK SPACED 33' MAXIMIM WITH ONE BREAK PER ROLL OF 1 SQUARE JM APPROVED SBS VAPOR RETARDER STAGGERED 10' MINIMUM.

COVER BOARD URETHANE ADHESIVE FASTENING - CBUA 12-6-4 DYNASET 1K RIBBON ADHERED BASE PLY **DS1K-3** Johns Marville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Marville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction. MEMBRANE TYPE: DYNASET 1K - CBUA ISSUE DATE MAXIMUM GUARANTEE TERM: DRAWN BY: HJV

Johns Manville