

ROLL PATCHES INTO SEAMS WITH
HAND ROLLER UNDER PRESSURE
AND CREASE INTO SEAMS
ACCORDING TO THE JM EPDM
APPLICATION GUIDE

12" x 12" (304 mm X 304 mm)
PATCH CUT FROM JM EPDM
12" PEEL & STICK FLASHING

JM SINGLE PLY
PRIMER (NOTE 4)

JM EPDM F.I.T.
(FACTORY INSEAM TAPE)

ALIGN MEMBRANE EDGES
SO THAT SEAM TAPE HAS
~1/8" EXPOSURE

JM EPDM F.I.T.
(FACTORY INSEAM TAPE)

JM EPDM F.I.T. SA
MEMBRANE

JM EPDM TAPE PRIMER
(NOTE 4)

JM EPDM SELF ADHERED
MEMBRANE ADHESIVE

JM INSULATION / COVER BOARD

APPROVED DECK

JM EPDM F.I.T. SA
MEMBRANE

JM 6" EPDM PEEL &
STICK SEALING STRIP

1" (25.4mm) MAX.
BUTT JOINT

JM SINGLE PLY
PRIMER (NOTE 4)

ISOMETRIC VIEW T-JOINT

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC) MUST BE APPLIED ON ALL MEMBRANE SURFACES COMING INTO CONTACT WITH JM EPDM PEEL & STICK PRODUCTS. ROLL MEMBRANE WITH HAND ROLLER UNDER PRESSURE AT SEAM IN ACCORDANCE WITH THE JM EPDM INSTALLATION GUIDE.
5. ALL EDGES WITH EXPOSED JM EPDM SELF ADHERED ADHESIVE MUST BE STRIPPED IN.

DRAWING NO.

E-MS-17


MEMBRANE SEAMING

JM EPDM SELF ADHERED SIDE LAP & T-JOINT

MEMBRANE TYPE:
JM EPDM SA

MAXIMUM GUARANTEE TERM:
25 YEAR

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Manville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction.



SCALE
N.T.S

ISSUE DATE
01-28-25