

- 2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
- 3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
- 4. ON DAYS WITH TEMPERATURES GREATER THAN 85° WHERE SHEETS ARE ALIGNED PRIOR TO RELAXING, OVERLAP SHALL BE 5" FOR 6" SEAM TAPE AND 3" FOR 4" SEAM TAPE TO ALLOW FOR PROPER SEAM ENGAGEMENT.
- 5. JM EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC) MUST BE APPLIED ON ALL SURFACES COMING INTO CONTACT WITH JM EPDM PEEL & STICK PRODUCTS.
 ROLL MEMBRANE WITH HAND ROLLER UNDER PRESSURE AT SEAM IN ACCORDANCE WITH THE JM EPDM INSTALLATION GUIDE.
- 6. 6" SEAM TAPE REQUIRED FOR 30 YEAR GUARANTEE TERM. FOR 90 mil MEMBRANE INSTALL A 12" X 12" PATCH CUT FROM JM EPDM 12" PEEL & STICK FLASHING CENTERED OVER THE T-JOINT PATCH PER DETAIL E-MS-PT3.

E-MS-PT2		EPDM MEMBRANE TAPE / STANDARD SHEET SIDE LAP & T-JOINT		
MEMBRANE SEAMING		MEMBRANE TYPE: JM EPDM	Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engine education and documentation required by any building code, contract, or applicable law. By	
SCALE N.T.S	1SSUE DATE 01-28-25	MAXIMUM GUARANTEE TERM: 25 YEAR	accepting the general conceptual information, you agree it does not constitute any representations,	Johns Manville